

VOC Content Test Certificate

Friday, 9th November 2018

Supplier: CW Brands Pty Ltd (21 Ballantyne Road, Kewdale, WA, 6105).

Sample Description: GSA Pro Seal 500

Date Tested: 29 October 2018 (Tested by FORAY Laboratories – NATA Accreditation 1224)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

| | |
|--|---|
| <p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Design & As Built V1.1 13.1.1</p> <p>Green Star Interiors V1.1 12.1.1B</p> | <p>GSA Pro Seal 500</p> |
| <p>Acoustic sealants, Architectural Adhesives and Sealants: 250 grams per Litre as VOC content per material</p> | <p>44 gram per Litre as VOC content per material</p> |
| <p><i>We hereby certify GSA Pro Seal 500 is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p> | |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV181049