

VOC Content Test Certificate

Friday 24th November 2023

Supplier: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills, NSW 2147, Australia)

Product Description: Ardex K275.

Date Tested: 29 April 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	ARDEX K275
General Purpose Adhesives and Sealants Limit: 50 grams per litre	2 grams per litre as VOC content per material
Meets GBCA VOC Content Requirement	Yes

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue date: 3/05/2024

Expiry date: 3/05/2029

P24040023